



EDGE OF PAVEMENT

TYPICAL CROSS SECTION

PED RAMP SECTION
4" CONCRETE OVER
2" CRUSHED ROCK



BOARDING/ALIGHTING AREA
4" CONCRETE OVER
2" CRUSHED ROCK

NOTES:

1. BOARDING/ALIGHTING AREA SHALL SLOPE TOWARDS THE ROADWAY AT 2%.
2. CONCRETE SHALL BE 4" THICK.
3. FINISHED WORK EXCEEDING MAXIMUM SLOPES OR LESS THAN MINIMUM DIMENSIONS WILL BE REJECTED. MAXIMUM AND MINIMUM VALUES ARE ABSOLUTE.

APPROVED BY:

POST FALLS STANDARDS FOR PUBLIC WORKS CONSTRUCTION

 3/19/19
CITY ENGINEER, P.E. DATE:

**BUS LANDING WITH NO CURB AND GUTTER
PRESENT**

STANDARD DRAWING
NO. **BD 04**