



NOTES:

1. VALVE BOXES SHALL BE TRAFFIC RATED H-20.
2. TRACER WIRE SHALL BE RUN TO AND TERMINATED INSIDE THE 2" GATE VALVE BOX.
3. WHERE VALVE BOXES ARE LOCATED IN PAVED AREAS THEY SHALL BE CONSTRUCTED WITH A THICKENED COLLAR AS PER SD 404.
4. A SADDLE TAP FROM THE "BLOW-OFF SECTION" IS AN ACCEPTABLE ALTERNATIVE TO TAPPING THE END CAP.

APPROVED BY:

POST FALLS STANDARDS FOR PUBLIC WORKS CONSTRUCTION

[Signature] 3/19/19
 CITY ENGINEER, P.E. DATE:

BLOW OFF DETAIL

STANDARD DRAWING
 NO. SD 410