



1. DRYWELLS SHALL BE CONSTRUCTED ON FREE-DRAINING SOILS. IF THESE SOILS ARE NOT PRESENT, A PERCOLATION TEST SHALL BE CONDUCTED TO VERIFY DESIGN CAPACITY.
2. FINISHED SWALE DEPTHS SHALL BE CONSTRUCTED AS SHOWN ON THE APPROVED PLANS. IN NO INSTANCE SHALL THE SWALE DEPTH BE LESS THAN 2" OR GREATER THAN 6" IN RESIDENTIAL AREAS OR GREATER THAN 8" IN COMMERCIAL AREAS.
3. SWALES MAY ALTERNATELY BE LOCATED BEHIND THE SIDEWALK WHEN SIDEWALK UNDERDRAINS ARE PROVIDED.
4. DRYWELLS SHALL BE LOCATED AT LEAST 3 FT. FROM THE NEAREST CURB CUT.

APPROVED BY:

POST FALLS STANDARDS FOR PUBLIC WORKS CONSTRUCTION

[Signature] 3/19/19
CITY ENGINEER, P.E. DATE:

**TYPICAL GRASSY SWALE
WITH DRYWELL DETAIL**

STANDARD DRAWING
NO. SD 601