


CITY OF POST FALLS Curb Ramp Inspection

Ramp ID Number or Specify New	Date Inspected	Inspected By (Print & Initial)
-------------------------------	----------------	--------------------------------

Intersection	Distance from Intersection
--------------	----------------------------

COMPLIANT	
(*All items must be within minimum/maximum tolerance to be compliant; do not leave blanks where measurements are required.)	
Yes*	No Provide Technical Infeasibility Reason & Explanation:

Ramp Location	Location in Intersection	Curb Ramp Type	Other (check any that apply)
<input type="checkbox"/> Corner <input type="checkbox"/> Mid-block	<input type="checkbox"/> N <input type="checkbox"/> E <input type="checkbox"/> NW <input type="checkbox"/> NE <input type="checkbox"/> S <input type="checkbox"/> W <input type="checkbox"/> SW <input type="checkbox"/> SE	<input type="checkbox"/> Perpendicular (1 Area) <input type="checkbox"/> Parallel (2 Areas) <input type="checkbox"/> Combined (3 Areas)	<input type="checkbox"/> Sidewalk <input type="checkbox"/> Curb & Gutter <input type="checkbox"/> Marked Crosswalk

Describe Ramp Location (details to help locate it, such as "facing Main Street next to the Shell station")

Refer to the Smart Level Measurement Locations detailed on Page 2

*Ramp Details (see attached)		Ramped Area 1	Ramped Area 2	Ramped Area 3	Ramped Area 4
Ramp Width (48" minimum)					
Ramp Description (Direction from Landing)					
1	Running Slope (8.3% maximum)				
2	Cross Slope (2% maximum)				
3	Flare Slope A (10% maximum)				
4	Flare Slope B (10% maximum)				

(5) Landing (Turning Space)

<input type="checkbox"/> Yes <input type="checkbox"/> No	Width (48" minimum)	Length (48" minimum)	(5) Cross Slope (2% maximum - both directions) W _____ L _____
---	---------------------	----------------------	--

***Detectable Warning Surface**

Detectable Warning Length (24" x 48")	Detectable Warning Spans Width of Curb Cut	Truncated Dome Spacing Correct as Noted on Standard Drawing
	<input type="checkbox"/> Yes <input type="checkbox"/> No (not compliant)	<input type="checkbox"/> Yes <input type="checkbox"/> No
Within 5' of the Curb Line/Grade Break	Color Contrast (e.g., Light on Dark or Dark on Light)	
<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	

***Transition Details (enter measurement)**

Lip Present (> ¼ inch)	(6) Gutter Flowline Slope at Ramp (2% maximum)	(7) Gutter Counter Slope (5% maximum)
<input type="checkbox"/> Yes (not compliant) <input checked="" type="checkbox"/> No		


Pedestrian Crossing Details

Pedestrian Signal Pushbutton	Pushbutton Height within 15" to 48"	Pushbutton within 10" of clear space	Crosswalk Clear Space
<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No (not compliant)	<input type="checkbox"/> Yes <input type="checkbox"/> No (not compliant)	<input type="checkbox"/> Yes <input type="checkbox"/> No (Provide Explanation in comment section)


Comments:

Ramp Compliant per City Standard SD 2013_____


ADA Ramp Inspection Details:

A ramp gradient measurement is required at locations marked with smart level below → 

Perpendicular Curb Ramp - 1 Ramped Area



Parallel Curb Ramp - 2 Ramped Areas



Combination Curb Ramp - 3 Ramped Areas

