

CITY OF POST FALLS STANDARD FOR P.V.B.A. INSTALLATION RE.: LANDSCAPE IRRIGATION SYSTEM

PRESSURE VACUUM BREAKER ASSEMBLY

ELEVATION REQUIREMENT:
12" MINIMUM, 60" MAXIMUM
ABOVE HIGHEST POINT IN
SYSTEM MUST BE MET.

BLOWOFF PORT
DOWNSTREAM OF P.V.B.A.
LOCATION MANDATORY.

UNIONS MANDATORY.

STOP AND WASTE VALVE.
ONE CUBIC FOOT OF CLEAN
DRAIN ROCK AT STOP & WASTE.

DRAIN ROCK

SPRINKER HEAD

ELEC. VALVES/STATIONS ALLOWED DOWNSTREAM.

DIRECTION OF FLOW TO SPRINKLERS

